



Jim Doyle, Governor
Mary P. Burke, Secretary

June 1, 2005

WIESER CONCRETE PRODUCTS, INC.
MARK WIESER
2815 RILEY ROAD
PORTAGE WI 53901

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: WIESER CONCRETE PRODUCTS, INC.
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, SEPTIC/SIPHON, HOLDING, PUMP,
SEPTIC/SEDIMENTATION OR GREASE INTERCEPTOR
Model Number(s): WLP 1000/650-FDL
(L.L. 41", 24.72/15.93 GAL/IN., 96" MAX. DEPTH OF BURY, 798 G.P.D. WHEN USED AS
A SEPTIC/SEPTIC TANK OR 485 G.P.D. WHEN USED AS A SEPTIC/PUMP OR
SEPTIC/SIPHON TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20050335

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2009.

This approval supercedes the approval issued on August 11, 2004, under product file number 20040353.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040353.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.

WIESER CONCRETE PRODUCTS, INC.

Page 2

June 1, 2005

Product File No: 20050335

- This product is approved to use the following:
 - Side opening for when product is used as a holding tank.
 - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Four inch discharge opening in riser.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual inlets at end of tank with one access opening above each inlet.
 - Internal divider wall (Detail 17 - Super Screen) in septic compartment located between 50% and 75% of the compartment length when measured from the inlet end of the compartment.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us