



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

February 1, 2006

DUTCH HOUSING, INC.  
BRADD GIGGY  
1500 N DETROIT ST  
PO BOX 258  
LAGRANGE IN 46761

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: DUTCH HOUSING, INC.  
Product Name: MODULAR HOME-PLUMBING TREE  
Model Number(s): DM19/DM20  
Product File No: 20050590  
Fee Received: \$200.00  
Date Received: 6/8/2005

We have reviewed the information we received from you for this plumbing product. However, we cannot continue our review until we receive the following:

Approval of the above product has been rescinded do to improper use of air admittance valve serving a clothes washer standpipe.

To regain approval, please submit two copies of revised plans that indicate the clothes washer standpipe and downstream piping complies to the requirements of the Wisconsin product approval for the air admittance valve serving the standpipe. The approval requires the following:

When an air admittance valve is installed to serve a standpipe receiving the discharge from a pumped-discharge type clothes washer, installation must comply with the following conditions:

- The standpipe and trap is at least 2" inch in diameter,
- The fixture drain between the trap and point of vent is at least 2" in diameter, and
- The fixture drain downstream of the point of vent is at least 3" in diameter.

A review of the information we requested will be completed within 40 working days following its receipt.

If after 6 months, a response to this letter has been received, a determination will be made based on the information at hand.

The product file number shown in the regarding line of this letter must be provided when contacting us about this product review.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov