



June 27, 2005

CONCRETE PRODUCTS, INC.  
TOM MUSSON  
1539 N. STEVENS ST.  
PO BOX 357  
RHINELANDER WI 54501-0357

ONEIDA CONCRETE PRODUCTS, INC.  
RICK JOHNSON  
  
PO BOX 357  
RHINELANDER WI 54501

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: ONEIDA CONCRETE PRODUCTS, INC.  
Product Name: HOLDING OR PUMP  
Model Number(s): 500  
(25.5 L.L., 21.49 GAL/IN, 72" MAX. DEPTH OF BURY)  
Product File No: 20050604

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2010.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Press Seal "Cast-A-Seal" gaskets
  - Dual or triple inlets at end of tank with one access or multiple openings above each inlet.
  - Dual or triple outlets end of tank with one access or multiple openings above each outlet.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - Tuf-Tite manhole risers and covers.
  - Bottom and side pipe openings for siphon, pump and holding tanks.
  - Six inch inlet and outlet openings.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on INSERT DATE under product file number 20002065#.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002065.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

CONCRETE PRODUCTS, INC.

Page 2

June 27, 2005

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: [mike.beckwith@wi.gov](mailto:mike.beckwith@wi.gov)