



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

July 19, 2005

COUNTY MATERIALS CORP.  
BILL MUELLER  
PO BOX 100  
MARATHON WI 54448

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: COUNTY MATERIALS CORP.  
Product Name: SEPTIC, HOLDING OR PUMP  
Model Number(s): 1250  
(43.5" L.L., 28.4 GAL/IN., 72" MAX. DEPTH OF BURY, 592 G.P.D. WHEN USED AS A  
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL  
WASTEWATER)  
Product File No: 20050623

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2009.

This approval supercedes the approval issued on August 12, 2004, under product file number 20040342.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040342.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product is installed as a septic tank, the minimum distance between the inlet(s) and outlet(s) must be at least equal to the length of the longest wall or the diameter of a circle that has the same surface area of the tank, whichever is less.

COUNTY MATERIALS CORP.

Page 2

July 19, 2005

Product File No: 20050623

- This product is approved to use the following:
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Cast-A-Seal by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc.
  - Dual inlets with one access opening above both inlets.
  - Dual inlets with one access opening above each inlet.
  - Inlet(s) and outlet(s) on opposite sides of tank, inlet(s) on end or side of tank with outlet on end of tank or interior wall.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - E-Z Set Lids and Risers installed in accordance with the E-Z Set Tank Company, Inc product approval issued by this department or cast into the concrete cover.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mbeckwith@commerce.state.wi.us