



8/30/2005 RE-ISSUED August 31, 2009

**ZABEL ENVIRONMENTAL TECHNOLOGY
PETER GAVIN
3 FAIRFILED BLVD
WALLINGFORD CT 06492**

Re: Description: **SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER (see also SEWAGE TREATMENT TANKS)***
Manufacturer: ZABEL ENVIRONMENTAL TECHNOLOGY
Product Name: A100-8 & A300-8 SERIES OF EFFLUENT FILTERS
Model Number(s): A100-8x12 (800 GPD), A100-8x18 (1200 GPD), A100-8x26 (1800 GPD), A100-8x32 (2400 GPD)
A300-8x12 (800 GPD), A300-8x18 (1200 GPD), A100-8x26 (1800 GPD), A300-8x32 (2400 GPD)
[A-100 SERIES = > 1/16 IN. FILTRATION; A-300 SERIES = > 1/32 IN. FILTRATION]
Product File No: 20050644

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2010.**

This approval is contingent upon compliance with the following stipulation(s):

- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product may only be installed in the outlet tee baffle of septic tanks or compartments that have a maximum daily flow rate of no more than: 800 gallons per day for models A100-8x12 and A300-8x12, 1200 gallons per day for models A100-8x18 and A300-8x18, 1800 gallons per day for models A100-8x26 and A300-8x26, 2400 gallons per day for models A100-8x32 and A300-8x32.
- **MAINTENANCE: Clean filter at inspection/pumping interval.**

This approval supersedes the approval issued on 8/30/2005 under product file number 20050644. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050644.

*** This product type category has been changed to better reflect it's use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STAF- sewage treatment apparatus, effluent filter only.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST; Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov