



May 23, 2006

ECOLOGICAL TANKS, INC.
JAMES K. CRAFT
2247 HWY 151 N
DOWNSVILLE LA 71234

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED
Manufacturer: ECOLOGICAL TANKS, INC.
Product Name: AQUA AIRE
Model Number(s): AA800-65
Product File No: 20050649

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2011.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less then or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- The maximum daily wastewater flow, which may discharge through this product, is 800 gallons per day.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov