



July 29, 2005

Revised 12/9/2011

CONINE MANUFACTURING CO., INC.  
GREG CONINE / JAY SCHULTZ

PO BOX 6561  
TYLER TX 75711

Re: Description: CAST IRON SOVENT SANITARY DRAINAGE, ALTERNATE PLUMBING SYSTEM  
Manufacturer: CONINE MANUFACTURING CO., INC.  
Product Name: CAST IRON SOVENT SINGLE-STACK DWV SYSTEM  
Model Number(s): NONE  
Product File No: 20050653

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.30 & 82.31 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of **April 2011**.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Any revisions to the 1990 manual require a revision approval prior to use under this approval.
- The entire system must be designed and installed in accordance with the 2004 copyright Sovent Cast Iron Single Stack DWV design manual number 802 requirements and recommendations.
- Written approval for the plumbing plans shall be obtained from the department for each installation of this system. If the project is located within the city of Milwaukee, plans may be submitted to either the department or to the city of Milwaukee.

This approval supersedes the approval issued on July 29, 2005 under product file number 20050653

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050653

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wi.gov