



Jim Doyle, Governor
Mary P. Burke, Secretary

October 10, 2005

CREST HOMES
DAVID N. RICHTER
437 N MAIN ST
PO BOX 1218
MIDDLEBURY IN 46540

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: CREST HOMES
Product Name: 1037
Model Number(s): 1037-**** W/OPTIONAL OPTIONAL BATH 1, OPTONAL BATH 1 WITH SHOWER, AND
BASEMENT VERSION
(**** INDICATES LENGTH AND WIDTH OF HOME)
Product File No: 20050710

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2011.

This approval supercedes the approval issued on January 23, 2001, under product file number 20002272.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002272.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 39 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us