

March 4, 2010

T.S.F. COMPANY, INC.
BOB SCHENK
2930 S. ST. PHILLIPS ROAD
EVANSVILLE IN 47712

Re: Description: **SEWAGE TANKS, RV TRANSFER CONTAINER**
Manufacturer: T.S.F. COMPANY, INC.
Product Name: HOLDING
Model Number(s): 225 (VOL 210)
Product File No: 20050747

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2010.

This approval is contingent upon compliance with the following stipulation(s):

- The joints between the tank cover and the inlets and outlet fittings must be made airtight.
- When this tank is installed to receive wastewater from only recreational vehicles, the tank must be installed by either a licensed plumber or a holder of a servicing license issued pursuant to s. 146.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code. All servicing and disposal of the contents from these tanks must be in accord with s. 146.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code.
- This product may only be used as a POWTS holding component in campgrounds permitted by the Department of Health and Family Services under ch. HFS 178.
- The solvent cement joints in the Over Flow Alarm Site Indicator must be made with an One Step cement in accordance with the cement manufacturer's instructions or s. Comm 84.40 (14) of the Wisconsin Administrative Code, which states which requires joint surfaces to be cleaned, a primer conforming to ASTM F656 applied to all joint surfaces, and solvent cement conforming to ASTM D2564 applied to all joint surfaces and the joint made while the cement is wet.

T.S.F. COMPANY, INC.
Page 2
March 4, 2010
20050747

This approval supersedes the approval issued on December 15, 2005 under product file number 20050747

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050747.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov