



November 21, 2005

ACCOR TECHNOLOGY, INC.
JERRY E. O'NEILL
1400 112TH AVE SE SUITE 100
BELLEVUE WA 98004

Re: Description: FIXTURE OR APPLIANCE SUPPLY CONNECTOR
Manufacturer: ACCOR TECHNOLOGY, INC.
Product Name: FLOW-TITE
Model Number(s): PO5-2** AND PO5-3** VALVES
 PO5-LS*~***, PO5-CS*~***, PO5-LP*~***, PO5-CP*~*** AND PO5-IP*~*** VALVES WITH
 ATTACHED RISER
 ASTERISKS DENOTE NUMBER OR LETTERS OF VARIATIONS WHICH DO NOT
 CHANGE THE APPROVED OPERATION OF THE BASE MODEL NUMBER SHOWN.

Product File No: 20050750

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (4)[c] based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The base model numbers for this product must be followed by the suffix X to be compatible with PEX, copper and CPVC pipe and/or tubing.
- This product may only be used as a fixture supply connector installed in accordance with s. Comm 82.40 (7) (h), Wis. Admin. Code.

This approval supersedes the approval issued on INSERT DATE under product file number 20000303.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000303.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov