



10/19/2005 re-issued September 15, 2009

**POLYLOK INC./ZABEL**  
PETER GAVIN  
3 FAIRFIELD BLVD  
WALLINGFORD CT 06492

Re: Description: **SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER\***  
Manufacturer: POLYLOK INC./ZABEL  
Product Name: EFFLUENT FILTER  
Model Number(s): 3014-525 and 3014-625  
[MAX. DWF = 10,000 GPD; FITS 4 OR 6 IN. DIA. OUTLET; SEE STIPULATIONS BELOW  
FOR SOLIDS DIAMETER CAPTURE]  
Product File No: 20050761

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2010.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- Model 3014-525 will prevent solids with a size greater than 1/16" in size from passing and model 3014-625 will prevent solids with a size greater than 1/32" in size from passing.
- **MAINTENANCE: Clean filter at inspection/pumping interval.**

This approval supersedes the approval issued on 10/19/2005 under product file number 20050761. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #20050761.

**\* This product type category has been changed to better reflect its use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STAF- sewage treatment apparatus, effluent filter only.**

#### **Company name and address change.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov