



Jim Doyle, Governor  
Mary P. Burke, Secretary

January 19, 2006

CRIVITZ REDI-MIX CO.  
MMC, INC.  
AL SCHULTZ  
2600 N ROEMER RD.  
PO BOX 1137  
APPLETON WI 54911

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: CRIVITZ REDI-MIX CO.  
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, GREASE INTERCEPTOR, HOLDING OR PUMP  
Model Number(s): 1200/800  
(49.5" L.L., 25.5/16.3 GAL/IN., 48" MAX. DEPTH OF BURY, 991 G.P.D. WHEN USED AS  
A SEPTIC/SEPTIC TANK OR 605 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK  
BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20050780

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2011.

This approval supersedes the approval issued on November 28, 2000, under product file number 20002162.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002162.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This product is approved to use the following:
  - 3/4" diameter opening in the access riser.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.

CRIVITZ REDI-MIX CO.  
Page 2  
January 19, 2006  
Product File No: 20050780

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mbeckwith@commerce.state.wi.us