



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Mary P. Burke, Secretary

November 4, 2005

ARJO, INC.
GARY LOFGREN
50 N GARY AVE
ROSELLE IL 60172

ARJO SWEDEN
GETINGE CASTLE GROUP
JOHN WENNBORG
VERKSTADSUAGEN 5
PO BOX 61, ESLOV, SWEDEN

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: ARJO SWEDEN
Product Name: FREEDOM BATH
Model Number(s): AFyywwsss-US
(yy = year of manufacture , ww = week of manufacture, sss = serial number)
Product File No: 20050788

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.41 (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Approval is issued for this product because the design of the product meets the intent of s. Comm 84.41 (3), Wis. Adm. Code that requires adequate protection of the potable water supply. The Watts N9 installed to serve the handheld shower is considered to provide adequate protection of the potable water serving this product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us