



November 2, 2005

DEPARTMENT OF COMMERCE
SAFETY AND BUILDINGS
KEN PERTZBORN
201 W WASHINGTON AVE
PO BOX 7162
MADISON WI 53707-7162

Re: Description: DENTAL MOLD GRINDER DISCHARGE TO A SINK, ALTERNATE PLUMBING SYSTEM
Manufacturer: DEPARTMENT OF COMMERCE
Product Name: ALTERNATE RECEPTOR FOR DENTAL MOLD GRINDER
Model Number(s): NONE
Product File No: 20050819

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.33 (8) (d) & 82.34 (13) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The sink serving as the receptor for the dental mold grinder shall be located within 3 feet of the grinder.
- The sink serving as a receptor for the dental mold grinder shall be provided with a plaster trap.
- The indirect waste piping of a dental mold grinder may discharge into the sink or to a sink branch tailpiece installed above the trap inlet. The connection shall be made by means of an air-gap or air-break.
- The indirect waste piping serving the dental mold grinder shall not exceed a length of 36 inches.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov