

December 19, 2005

ONEIDA CONCRETE PRODUCTS, INC.
TOM MUSSON
1539 N. STEVENS ST.
PO BOX 357
RHINELANDER WI 54501-0357

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: ONEIDA CONCRETE PRODUCTS, INC.
Product Name: HIGH STRENGTH FAST 1.5
Model Number(s): 2500 TANK WITH TREATMENT SYSTEM
Product File No: 20050901

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2010.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This product is approved to use the following:
 - Press Seal "Cast-A-Seal" gaskets
 - Dual or triple inlets at end of tank with one access or multiple openings above each inlet.
 - Dual or triple outlets end of tank with one access or multiple openings above each outlet.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Tuf-Tite manhole risers and covers.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may only be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- The maximum daily wastewater flow which may discharge through this product is 1500 gallons per day.

This approval supersedes the approval issued on March 27, 2001, under product file number 20010049.

ONEIDA CONCRETE PRODUCTS, INC.

Page 2

December 19, 2005

Product File No: 20050901

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010049.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: mbeckwith@commerce.state.wi.us