



January 12, 2006

GROVE CONCRETE & SUPPLY, INC.
PAUL J. MILLER, SR.
18426 DURAND AVE.
PO BOX 363
UNION GROVE WI 53182

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: GROVE CONCRETE & SUPPLY, INC.
Product Name: CLEARSTREAM 600 GPD TANK
Model Number(s): 600 NC
Product File No: 20050913

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2011.

This approval supersedes the approval issued on September 19, 2000, under product file number 20002067.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002067.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 600 gallons per day.
- This product may not be installed more than 18 inches below final grade.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- A septic tank (pretreatment tank/trash trap) with a volume of at least 50% of the gallon per day rating of this product must be installed upstream of this product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742, fax: 608-267-9566
e-mail: mbeckwith@commerce.state.wi.us