

May 20, 2009

REVISED 5/20/2009

CASH ACME
RELIANCE WORLDWIDE
WILLIAM CHAPIN
2400 7TH AVE SW
CULLMAN AL 35055

Re: Description: FITTINGS, COPPER, CPVC OR PEX
Manufacturer: CASH ACME
Product Name: SHARKBITE PUSH-FIT FITTING
Model Number(s): STRAIGHT COUPLING: U008, 1/2x1/2; U016, 3/4x3/4; U020, 1x1; STRAIGHT COUPLING
REDUCING: U058, 3/4x1/2; U060, 1x3/4; STRAIGHT CONNECTOR: U072, 1/2x1/2 F NPT;
U120, 1/2x1/2 M NPT; U068, 1/2x3/4 F NPT; U088, 3/4x3/4 F NPT; U134, 3/4x3/4 M NPT,
U094, 1x1 F NPT; U140, 1x1 M NPT; U142, 1x3/4 M NPT; ELBOW: U248, 1/2x1/2; U308,
1/2x1/2 F NPT; U280, 1/2x1/2 M NPT; U334, G1/2x1/2; U350, G1/2Bx1/2; U352 G1/2Bx1/2
(ext 100); U256, 3/4x3/4; U274, 3/4x1/2; U260, 1x1; DROP EAR ELBOW: 1/2x1/2; HI-EAR
ELBOW: 1/2x1/2; TEE: U362, 1/2x1/2x1/2; U370, 3/4x3/4x3/4; U412, 3/4x3/4x1/2; U444,
3/4x1/2x3/4; U454, 3/4x1/2x1/2; U374, 1x1x1; U412, 1x1x3/4; STOP END: U514, 1/2; U518,
3/4, U520, 1; PLUG: U755, 1/2; U756, 3/4; U757, 1; ADAPTER STRAIGHT: U760, 1/2 TAIL
x 1/2 F NPT; U764, 3/4 TAIL x 1/2 F NPT; U766, 3/4 TAIL x 3/4 F NPT; U750, 1 TAIL x 3/4
M NPT; U752, 1 TAIL x 1 M NPT; REDUCER ADAPTOR STRAIGHT: U740, 1/2 TAIL x 1/2
M NPT; U720, 3/4 TAIL x 1/2 CARTRIDGE; U744, 3/4 TAIL x 1/2 M NPT; U746, 1 TAIL x
3/4 M NPT; U722, 1 TAIL x 1/2mm CARTRIDGE; U724, 1 TAIL x 3/4mm CARTRIDGE;
CHECK VALVE: U2008, 1/2x1/2; U2016, 3/4x3/4.
U3088FLEX12, (3/4" push-fit x 3/4" NPSM -12) U3088FLEX15, (3/4" push-fit x 3/4" NPSM-15)
U3088FLEX18, (3/4" push-fit x 3/4" NPSM -18) U3088FLEX24, (3/4" push-fit x 3/4" NPSM-24)
Product File No: 20050922

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2011.

This approval is contingent upon compliance with the following stipulation(s):

- The fittings must be labeled with the manufacturer's name or trade mark, size and tubing material for which the fitting is intended to connect together.
- This product may be used to join together copper that complies with ASTM B88, CPVC that complies with ASTM D2846 or CSA B137.6 and PEX that complies with ASTM F876 or ASTM F877.

This approval supersedes the approval issued on May 11, 2005 under product file number 20050273.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #20050273.

CASH ACME
Page 2
MAY 20 2009
20050922

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov