



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

January 20, 2006

MANUFACTURED HOUSING ENTERPRISES  
JOHN H. BAILEY  
09302 STATE ROUTE 6  
BRYAN OH 43506

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: MANUFACTURED HOUSING ENTERPRISES  
Product Name: THE WINDSOR  
Model Number(s): M48B02  
Product File No: 20050934

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2011.

This approval supersedes the approval issued on May 17, 2001, under product file number 20010183.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010183.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 38 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mbeckwith@commerce.state.wi.us