



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

February 2, 2006

HOLLY PARK  
INDIANA BUILDING SYSTEMS, LLC  
ERIK SMITH  
51700 LOVEJOY DR  
MIDDLEBURY IN 46540

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: HOLLY PARK  
Product Name: MODULAR HOMES-DWV LINES  
Model Number(s): CAMDEN-MODEL 813M  
Product File No: 20060015

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2011.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 34 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.
- The air admittance valve must be an approved product by this office and installed in accordance with its approval by this office.
- When an air admittance valve is installed to serve a standpipe receiving the discharge from a pumped-discharge type clothes washer, installation must comply with the following conditions:
  - The standpipe and trap is at least 2" inch in diameter,
  - The fixture drain between the trap and point of vent is at least 2" in diameter, and
  - The fixture drain downstream of the point of vent is at least 3" in diameter.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov