



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Mary P. Burke, Secretary

March 1, 2006

NTA, INC.
KRISTEN CUMBERLAND
305 N OAKLAND AVE
PO BOX 490
NAPPANEE IN 46550

RITZ-CRAFT CORP.OF PA, INC.
RITZ-CRAFT CORP.OF MI.,INC.
TEDD BRUNGARD
15 INDUSTRIAL PARK RD
PO BOX 70
MIFFLINBURG PA 17844

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: RITZ-CRAFT CORP.OF PA, INC.
Product Name: TWO STORY RANCH-DWV LINES
Model Number(s): L TWO STORY LT 0106
Product File No: 20060018

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2011.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 20 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov