



Jim Doyle, Governor  
Mary P. Burke, Secretary

February 21, 2006

NVENT LLC  
PETER SHARKEY  
2834 MITCHELL AVE  
ALLENTOWN PA 18103

Re: Description: FITTINGS, COPPER  
Manufacturer: NVENT LLC  
Product Name: NVENT PERMALYNX  
Model Number(s): VALVES: PL500, 1/2 - 2; PL500-2, 1/2 - 2; PL510, 1/2 - 2; PL200, 1/2 - 2; PL200-2, 1/2 - 2; PL200-HC, 1/2 - 2; FITTINGS: PLCAP: PL617, 1/2 - 2; COUPLING: PL600, 1/2 - 2; PL600R, 3/4 - 2; PL600-2R, 1/2 - 3/4; 45° ELBOW: (STANDARD) PL606, 1/2 - 2; (FITTING) PL606-2, 1/2 - 2; 90° ELBOW: (STANDARD) PL607, 1/2 - 2; (FITTING) PL607-2, 1/2 - 2; (LONG) PL607LT, 1/2 - 2; (SHORT) PL607R, 3/4; (DROP) PL707-5, 1/2; (TEE) PL611, 1/2 - 2; (BULLHEAD) PL611BH, 1/2 - 3/4; PL611R, 3/4 - 2; PL611RR, 3/4; UNION: PL733, 1/2 - 2; PL733-3, 1/2 - 1; PL733-4, 1/2 - 1; COUPLING: PL603, 1/2 - 2; PL603R, 1/2 - 1; PL604, 1/2 - 2; PL604, 1/2 - 3/4 90° ELBOW: PL707-3, 1/2 - 1; PL707-3-5, 1/2 - 3/4; PL707-4, 1/2 - 1; TEE: PL712, 1/2 - 1; and FLANGE: PL771, 1 - 2 (all sizes are in inches)  
Product File No: 20060022

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (8)© based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following use(s)
  - a. Water distribution piping . . . . aboveground
  - b. Water distribution piping . . . . belowground
  - c. Water service pipe
- This product may be used to join together copper that complies with ASTM B88.
- The fittings must be labeled with the manufacturer's name or trade mark and fitting size.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wi.gov