



March 2, 2006

WEIS CAST  
WEIS EXCAVATING INC.  
DALE WEIS

PO BOX 340  
JOHNSON CREEK WI 53038-0340

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: WEIS CAST  
Product Name: SEPTIC, HOLDING, GREASE INTERCEPTOR OR PUMP  
Model Number(s): 1000  
(50" L.L., 21.02 GAL/IN., 96" MAX. DEPTH OF BURY, 503 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20060028

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
  - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - Neenah Foundry Co., self-sealing manhole cover.
  - Conseal CS 301 or 302 or Press Seal CPS or equal joint sealant for tank wall, tank cover and riser joints.

A copy of the approved plans and/or specifications is enclosed.

This approval supersedes the approval issued on INSERT DATE under product file number #####.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #####.

WEIS CAST  
Page 2  
March 2, 2006

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: [mike.beckwith@wisconsin.gov](mailto:mike.beckwith@wisconsin.gov)