



April 3, 2006

LEDGEVIEW PRECAST CONCRETE, INC.  
ALLEN E. FREUND  
N6672 COUNTY TRUNK UU  
FOND DU LAC WI 54935

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: LEDGEVIEW PRECAST CONCRETE, INC.  
Product Name: SEPTIC, HOLDING, PUMP, SEDIMENTATION OR GREASE INTERCEPTOR  
Model Number(s): 800  
(44.0" L.L., 18.4 GAL/IN., 388 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3  
YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20060102

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2011.

This approval supersedes the approval issued on January 28, 2004, under product file number 20040010.

A copy of the additional or revised portions of the approved plans and/or specifications is enclosed. The plans and/or specifications shall be incorporated with your previous approval under product file number 20040010.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Two inch PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" gaskets.
  - Dual inlets at end of tank with an access opening above one inlet and an observation opening over the other inlet.
  - Bottom pipe openings for pump and holding tanks.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.

LEDGEVIEW PRECAST CONCRETE, INC.

Page 2

April 3, 2006

Product File No: 20060102

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: [mike.beckwith@wisconsin.gov](mailto:mike.beckwith@wisconsin.gov)