



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

December 27, 2006

CONTECH CONSTRUCTION PRODUCTS, INC.  
ROBERT G MOORE  
11155 CHAPARRAL AVE  
SHAKOPEE MN 55379

CONTECH CONSTRUCTION PRODUCTS INC.  
TODD M. RIEBAU  
6441 ENTERPRISE LANE SUITE 116  
MADISON WI 53719

Re: Description: PIPES AND FITTINGS, ALUMINIZED STEEL (SEE ALSO STORMWATER DETENTION SYSTEMS)  
Manufacturer: CONTECH CONSTRUCTION PRODUCTS INC.  
Product Name: CONTECH ULTRA-FLOW ALT2 STORM SEWER PIPE; STORMWATER DETENTION PIPING  
Model Number(s): 2 2/3" X 1/2" CORRUGATED PIPE AND H-12 DOUBLE BOLT, BAR AND STRAP HUGGER  
BAND WITH BACK UP PLATE AND O RING GASKETS: 12" AND 15"  
Product File No: 20060138

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This product must conform to American Association of State Highway and Transportation Officials (AASHTO) standard M36/M 36M-90.
- This product may be installed for the following drain and vent use(s):
  - a. Storm sewer . . . . . gravity flow
- The review undertaken by Commerce staff does not include review and/or approval of this submittal as meeting DNR specifications for ch. NR 151.
- This product is approved for the following use:
  - Stormwater and clearwater subsurface detention system.
- When this product is installed as a subsurface detention system, the installation must be in accordance with the manufacturer's printed instructions. When there is a conflict between the manufacturer's installation instructions and plan approval or product approval stipulations, the plan approval or product approval stipulations will take precedence.

Sizing of piping for stormwater and clearwater subsurface detention shall be made using hydraulic calculations as specified in manufacturer's instructions.

This approval supersedes the approval issued on INSERT DATE under product file number 20010003.

CONTECH CONSTRUCTION PRODUCTS, INC.

Page 2

December 27, 2006

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010003.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov