



MAY 15, 2006 RE-ISSUED September 15, 2009

POLYLOK INC./ZABEL
PETER GAVIN
3 FAIRFIELD BLVD
WALLINGFORD CT 06492

Re: Description: **SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER***
Manufacturer: POLYLOK INC./ZABEL
Product Name: A100 -12 and A300-12 EFFLUENT FILTER SERIES
Model Number(s): A100-12x20-VC, A100-12x20-VCF, A100-12x28-VC, A100-12x28-VCF, A100-12x36-VC, A100-12x36-VCF, A101-12x20, A100-12x28, A100-12x36, A300-12x20VC, A300-12-x20-VCF, A300-12x28-VC, A300-12x28-VCF, A300-12x36-VC, A300-12x36-VCF, A301-12x20, A301-12x28 AND A301-12x36
[A-100 SERIES >1/16 IN. FILTRATION; A-300 SERIES > 1/32 IN. FILTRATION; SEE STIPULATION BELOW FOR DWF]
Product File No: 20060178

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of AUGUST 2011.**

This approval is contingent upon compliance with the following stipulation(s):

- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product may only be installed in the outlet tee baffle of septic tanks or compartments that have a maximum daily flow rate of no more than; 3000 gallons per day for models A100-12x20-VC, A100-12x20-VCF, A101-12x20, A300-12x20-VC, A300-12x20-VCF, and A301-12x20; 4500 gallons per day for models A100-12x28-VC, A100-12x28-VCF, A101-12X28, A300-12x28-VC, A300-12x28-VCF, and A301-12x28; 6000 gallons per day for models A100-12x36-VC, A100-12x36-VCF, A101-12x36, A300-12x36-VC A300-12x36-VCF, and A301-12x36.
- **MAINTENANCE: Clean filter at inspection/pumping interval.**

This approval supersedes the approval issued on 5/19/2006 under product file number 20060178. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060178.

*** This product type category has been changed to better reflect its use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STAF- sewage treatment apparatus, effluent filter only.**

Company name and address change. The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov