



5/15/2006 RE-ISSUED September 11, 2009

QUANICS, INC.
BRIAN BORDERS
PO BOX 1520
CRESTWOOD KY 40014

Re: Description: **SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT ***
Manufacturer: QUANICS, INC.
Product Name: ZEUS BASIN ASSEMBLIES
Model Number(s): RB-BAS-20x38, RB-BAS-22x38 AND RB-BAS-26x38
20"x38": (34 GALS, 25.0" L.L., 6" MAX. DEPTH OF COVER); 22"x38": (41 GALS, 25.0" L.L., 6"
MAX. DEPTH OF COVER); 24"x38": (49 GALS, 25.0" L.L., 6" MAX. DEPTH OF COVER)
Product File No: 20060181

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end AUGUST 2010.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use a department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- **The capacity of the sedimentation tank is exempt from the minimum capacity requirements of s. Comm 83.15 (3) of the Wis. Admin. Code. This tank capacity must not be included in the septic tank capacity required by s. Comm 83.15 (3) of the Wis. Admin. Code.**
- **Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.**
- **Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.**

This approval supersedes the approval issued on 5/15/2006 under product file number 20060181. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060181.

*** This product type category has been changed to better reflect its use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STAFCV- sewage treatment apparatus, container/vault.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov