



May 15, 2006 RE-ISSUED 7/24/08

QUANICS, INC.
BRIAN BORDERS
PO BOX 1520
CRESTWOOD KY 40014

Re: **Description:** **SEWAGE TANK COVERS, LIDS, RISERS**
Manufacturer: QUANICS, INC.
Product Name: ZEUS ACCESS SYSTEM RISERS AND LIDS
Model Number(s): 20 INCH: RB-L-20; RB-RTA-20x2; RB-CTA-20x6; RB-R-20x6; RB-R-20x12 and RB-R-20x38
22 INCH: RB-L-22; RB-RTA-22x2; RB-CTA-22x6; RB-R-22x6; RB-R-22x12 and RB-R-22x38
26 INCH: RB-L-26; RB-RTA-26x2; RB-CTA-26x6; RB-R-26x6; RB-R-26x12 and RB-R-26x38
TANK ADAPTER: RB-PTA-26x2
Product File No: 20060182

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2011.**

This approval is contingent upon compliance with the following stipulation(s):

- The manhole cover must be secured to the riser using screws which are not standard or phillips head to be considered an effective locking device.
- Joints between riser sections shall be seal with neoprene gasket supplied by the manufacturer and the riser must be installed on existing tanks in accordance with the riser manufacturer's installation instructions.

This approval supersedes the approval issued on 10/20/2005 under product file number 20050777. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050777.

TO ASSIST USERS IN ON-LINE SEARCHES FOR COMMERCE PLUMBING PRODUCT APPROVALS AND TO BETTER DESCRIBE THIS PART/DEVICE, AS OF THE DATE OF THIS COMMUNICATION, THIS PRODUCT TYPE DESCRIPTION HAS BEEN CHANGED FROM SEWAGE TREATMENT APPARATUS (STA) TO SEWAGE TANK COVERS, LIDS AND RISERS (STCOVR); SEE ALSO http://commerce.wi.gov/php/sb-ppalopp/prodcode_alpha_list.php.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov