

June 14, 2006

DELTA ENVIRONMENTAL PRODUCTS
MIKE CATANZARO
PO BOX 969
DENHAM SPRINGS LA 70727

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED
Manufacturer: DELTA ENVIRONMENTAL PRODUCTS
Product Name: ECOPOD
Model Number(s): E50FF02 (500 GPD)
Product File No: 20060207

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2011.

This approval supersedes the approval issued on June 9, 2006, under product file number 20060207.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060207.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- This product's tank top must be buried between 12 inches and 48 inches below finished grade.

DELTA ENVIRONMENTAL PRODUCTS

Page 2

June 14, 2006

Product File No: 20060207

- This product may have the Aermotor S series (Stainless Steel) or T series (Thermax) 12, 16 or 20 gallon per minute pumps. Pump curve information may be obtained at www.aermotor.com.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov