



August 24, 2006

NOVEON
TEMPRITE
TINA MASSEL
9911 BRECKSVILLE RD
BRECKSVILLE OH 44141

NIBCO INC.
1516 MIDDLEBURY ST
MARK CLARK
P O BOX 1167
ELKHART IN 46515-1167

Re: Description: FITTINGS, CPVC
Manufacturer: NIBCO INC.
Product Name: NIBCO / CHEMTROL CORZAN CPVC SCHEDULE 80 FITTINGS
Model Number(s): SCHEDULE 80 FITTINGS (ASTM F 437 OR F 439) IN 3", 4", 6", 8", 10" and 12" SIZE.
Product File No: 20060317

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (4)(e)1 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The fittings that conform to ASTM F 439 shall be labeled with manufacturer's name or trade mark, material designation CPVC for CPVC 23447 and CPVC 42 for CPVC 23448, the seal or mark of the laboratory making the evaluation for potable water contact, size, and this designation "F 439," with which the fitting complies.

Where the size of the fitting does not allow complete marking, omit identification marking in the following sequence: size, material designation, F 439, and the manufacturer's name or trademark.

- The fittings that conform to ASTM F 437 shall be labeled with manufacturer's name or trade mark, material designation CPVC for CPVC 23447, the seal or mark of the laboratory making the evaluation for potable water contact, size, and this designation "F 437," with which the fitting complies.

Where the size of the fitting does not allow complete marking, omit identification marking in the following sequence: size, material designation, F 437, and the manufacturer's name or trademark.

- This product may be installed for the following water use(s):
 - a. Cold water distribution piping Aboveground
 - b. Cold water distribution piping Underground

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov