



August 17, 2006

ENFORCER PRODUCTS  
A DIVISION OF ACUIITY SPECIALTY PRODUCTS  
KELLIE DIXON  
1420 SEABOARD INDUSTRIAL BLVD  
ATLANTA GA 30318

Re: Description: CHEMICAL OR BIOCHEMICAL SEPTIC TANK ADDITIVE  
Manufacturer: ENFORCER PRODUCTS  
Product Name: DRAIN CARE SEPTIC TANK TREATMENT  
Model Number(s): ST-16  
Product File No: 20060323

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2011.

This approval is contingent upon compliance with the following stipulation(s):

- If the formulation of this approved septic tank additive is modified, or additional assertions of function or performance are made, then this approval shall be rendered null and void, unless the change is submitted to this department for review and the approval reaffirmed.
- This product does not replace the need for a regular program of inspection and maintenance. This includes having the tank pumped out when the volume of sludge and/or scum occupies one-third of the tanks liquid capacity.
- Based on information supplied by the manufacturer and reviewed by this department, the approval for this product recognizes this septic tank additive will not adversely affect the user, the bacterial action in septic systems, the soil hydraulic conductivity in soil absorption areas, or groundwater quality, when used in accordance with the manufacturers instructions.

This approval supersedes the approval issued on INSERT DATE under product file number 20010351

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

ENFORCER PRODUCTS

Page 2

August 17, 2006

Sincerely,

Glen W. Schlueter  
Engineering Consultant-Plumbing Product Reviewer  
Bureau of Integrated Services  
Safety and Buildings Division  
Department of Commerce  
(608) 267-1401 Phone  
(608) 267-9566 Fax  
gschlueter@commerce.state.wi.us Email

GWS:gws