



October 30, 2006 **RE-ISSUED 7/23/2008**

SIM / TECH FILTER
KOTESKEY BROTHERS EXCAVATING INC.
GARY KOTESKEY
06598 HORTON BAY N RD.
BOYNE CITY MI 49712

Re: Description: SEWAGE TANK COVERS, LIDS, RISERS
Manufacturer: SIM / TECH FILTER
Product Name: RISER AND RELATED PARTS
Model Number(s): STF-R824 RISER; STF-CI24 CAST IRON COVER; STF-APC24B or STF-APC24G
POLYCARBONATE COVER; STF-AR24 TANK ADAPTER RING; and STF-N24
SECURITY NET W/MOUNTING HARDWARE
Product File No: 20060348

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2011.**

This approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in accordance with the manufacturer's installation instructions and the following requirements:
 1. Mechanical fasteners must be used to mount the STF-AR24 Adapter Ring to top of tank.
 2. Silicone rubber sealant must applied to the horizontal joint between riser sections.
 3. A minimum of three 1 to 1-1/4 inch #8 or #10 stainless steel screws must be used to secure the bottom and top riser sections together. The screws must be equally spaced around the riser.
 4. Risers must be backfilled with sand or installed with a frost shield.
 5. An acceptable locking device must be used to secure riser cover.

This approval supersedes the approval issued on 10/28/2003 under product file number 20030149. A copy of the additional or revised portions of the approved plans and/or specifications is enclosed. The plans and/or specifications shall be incorporated with your previous approval under product file number 20030149.

TO ASSIST USERS IN ON-LINE SEARCHES FOR COMMERCE PLUMBING PRODUCT APPROVALS AND TO BETTER DESCRIBE THIS PART/DEVICE, AS OF THE DATE OF THIS COMMUNICATION, THIS PRODUCT TYPE DESCRIPTION HAS BEEN CHANGED FROM SEWAGE TREATMENT APPARATUS (STA) TO SEWAGE TANK COVERS, LIDS AND RISERS (STCOVR); SEE ALSO http://commerce.wi.gov/php/sb-ppalopp/prodcode_alpha_list.php.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov