



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

September 25, 2006

INVACARE CORPORATION  
INVACARE CONTINUING CARE GROUP  
DALE KEMPER  
1644 LOTSIE BLVD  
ST LOUIS MO 63132

Re: Description: HEALTH CARE PLUMBING APPLIANCE  
Manufacturer: INVACARE CORPORATION  
Product Name: SUPINE, FREE STANDING, HYDRO-THERAPY WHIRLPOOL BATH TUB  
Model Number(s): IH6300-FIXED HEIGHT  
IH6300ADH-ADJUSTABLE HEIGHT  
Product File No: 20060393

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This product is supplied from the manufacture with atmospheric vacuum breakers conforming to ASSE 1001 installed in the products water piping. One of them located between the mixing valve and the hand held shower and the other located between the mixing valve and the disinfectant injector (vacuum venturi). Both backflow protection devices at installed at a height of at least 6 inches above the highest point downstream from the device where backpressure would be created.
- This product must discharge its waste to an acceptable receptor in accordance with s. Comm 82.33 (8) of the Wis. Adm. Code.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov