



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Mary P. Burke, Secretary

November 15, 2006

CITY OF MEQUON
ENGINEERING
MARK LLOYD
11333 N CEDARBURG RD
MEQUON WI 53092

SANIPOR VERTRIEBS GMBH
INTERNATIONAL MARKETING
CSILLA PALL
OELBERGRING 32B-D-83620,
FELDKIRCHEN-WESTERHAM,
GERMANY

Re: Description: PIPE LINER
Manufacturer: SANIPOR VERTRIEBS GMBH
Product Name: SANIPOR
Model Number(s): N/A
Product File No: 20060406
Fee Received: \$300.00
Date Received: 9/12/2006

We have reviewed the information we received from you for this plumbing product. However, we cannot continue our review until we receive the following:

- Documentation that the product will product a "watertight" building sewer that will hold 10 feet head of water or 5 psig of air for 15 minutes without any leakage. Please note that we realize that municipal sewer systems allow some leakage, however plumbing system that is under our jurisdiction does not allow any leakage when tested to one of the above tests.

A review of the information we requested will be completed within 3 months following its receipt.

If after 6 months, a response to this letter has been received, a determination will be made based on the information at hand.

The product file number shown in the regarding line of this letter must be provided when contacting us about this product review.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov