



Jim Doyle, Governor
Mary P. Burke, Secretary

October 16, 2006

ELKHART PRODUCTS CORPORATION
JOHN WATSON
1255 OAK ST
PO BOX 1008
ELKHART IN 46515

Re: Description: FITTINGS, COPPER, CPVC OR PEX
Manufacturer: ELKHART PRODUCTS CORPORATION
Product Name: QTITE PUSH-FIT JOINING SYSTEM
Model Number(s): 900-8 COUPLING, 1/2"; 900-12 COUPLING, 3/4"; 900-16 COUPLING, 1"; 901R-12-8 REDUCING COUPLING, 3/4"x1/2"; 901R-168 REDUCING COUPLING, 1"x1/2"; 901R-1612 REDUCING COUPLING, 1"x3/4"; 903-8 FEMALE ADAPTER, 1/2"; 903-12 FEMALE ADAPTER, 3/4"; 903-16 FEMALE ADAPTER, 1"; 904-8 MALE ADAPTER, 1/2"; 904-12 MALE ADAPTER, 3/4"; 904-16 MALE ADAPTER, 1"; 906-8 45 DEGREE ELBOW, 1/2"; 906-12 45 DEGREE ELBOW, 3/4"; 906-16 45 DEGREE ELBOW, 1"; 907L-8 90 DEGREE ELBOW, 1/2"; 907L-12 90 DEGREE ELBOW, 3/4"; 907-16 90 DEGREE ELBOW, 1"; 907-3-12 90 DEGREE C x F ELBOW, 3/4"; 911-8 TEE, 1/2"; 911-12 TEE, 3/4"; 911-16 TEE, 1"; 911-12128 TEE, 3/4"x3/4"x1/2"; 911-16168 TEE, 1"x1"x1/2"; 911-16162 TEE, 1"x1"x3/4"; AND 97073-8 90 DREGEE DROP EAR ELBOW, 1/2".
Product File No: 20060407

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (5)(a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The fittings must be labeled with the manufacturer's name or trade mark, size and tubing material for which the fitting is intended to connect together.
- This product may be used to join together copper that complies with ASTM B88, CPVC that complies with ASTM D2846 or CSA B137.6 and PEX that complies with ASTM F876 or ASTM F477.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov