



Jim Doyle, Governor
Mary P. Burke, Secretary

October 17, 2006

ELKHART PRODUCTS CORPORATION
JOHN WATSON
1255 OAK ST
PO BOX 1008
ELKHART IN 46515

Re: Description: FITTINGS, COPPER, CPVC OR PEX
Manufacturer: ELKHART PRODUCTS CORPORATION
Product Name: TECTITE REMOVABLE PUSH-FIT JOINING SYSTEM
Model Number(s): 200-8 COUPLING, 1/2"; 200-12 COUPLING, 3/4"; 201R-128 REDUCING COUPLING, 3/4"x1/2"; 203-8 ADAPTER, 1/2"x1/2" NPT FEMALE; 203-12 ADAPTER, 3/4"x3/4" NPT FEMALE; 204-8 ADAPTER, 1/2"x1/2" NPT MALE; 204-12 ADAPTER, 3/4"x3/4" NPT MALE; 207-8 90 DEGREE ELBOW, 1/2"; 207-12 90 DEGREE ELBOW, 3/4"; 211-8 TEE, 1/2"; 211-12 TEE, 3/4"; 211-12128 REDUCING TEE, 3/4"x3/4"x1/2"; 217-8 TUBE CAP, 1/2"; 217-12 TUBE CAP, 3/4"; 2707-3-8 DROP EAR, 1/2"x1/2" NPT.
Product File No: 20060408

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (5)(a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The fittings must be labeled with the manufacturer's name or trade mark, size and tubing material for which the fitting is intended to connect together.
- This product may be used to join together copper that complies with ASTM B88, CPVC that complies with ASTM D2846 or CSA B137.6 and PEX that complies with ASTM F876 or ASTM F477.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov