



November 13, 2006

ACORN ENGINEERING COMPANY
FARHAD SHAHRIARY
15125 PROCTOR AVE
CITY OF INDUSTRY CA 91746

Re: Description: WASHFOUNTAIN
Manufacturer: ACORN ENGINEERING COMPANY
Product Name: WASH-WARE WASHFOUNTAINS
Model Number(s): 3401, 3402, 3411, 3412, 3422, 3423, 3424, 3432, 3433, 3434, 3442, 3443,
3452, 3453, 3463, 3464, 3482, 3483, 3506, 3508, 3543, 3544, 32512, 32513,
3601, 3603, 3604 AND 3612
Product File No: 20060433

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.32(4)(b)1. based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of December 2011.**

This alternate approval is contingent upon compliance with the following stipulation(s):

- Wash fountains which have more than seven stations may not be operated by non-sectional controls.
- Wash fountains installed in public toilet rooms must have the metering Air-trol valves adjusted to allow a maximum of one gallon of water to be discharged after the valve is activated.

This approval supersedes the approval issued on INSERT DATE under product file number 20010544.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #20010544.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov