



November 13, 2006

ACORN ENGINEERING COMPANY
FARHAD SHAHRIARY
15125 PROCTOR AVE
CITY OF INDUSTRY CA 91746

Re: Description: FAUCET, LAVATORY
Manufacturer: ACORN ENGINEERING COMPANY
Product Name: MANIFOLDED AIR CONTROL VALVE ASSEMBLY
Model Number(s): -03-MA2, -03-MA3, -03-MA4, -04-MA2, -04-MA3 AND -04,MA4
Product File No: 20060434

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2012.

This approval is contingent upon compliance with the following stipulation(s):

- Approval is issued for this product because the design of the product meets the intent of s. Comm 82.40 (4)(c)1.b., Wis. Adm. Code that requires a control valve in fixture supply to each plumbing fixture. The intent of the code is met since this product provides an acceptable method of valving up to four lavatory faucets in a penal setting.

This approval supersedes the approval issued on INSERT DATE under product file number 20010578.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010578.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov