



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor
Mary P. Burke, Secretary

November 15, 2006

KAY CHEMICAL COMPANY
TIM BOTTS
8300 CAPITAL DR
GREENSBORO NC 27409

Re: Description: PROPORTIONER
Manufacturer: KAY CHEMICAL COMPANY
Product Name: TWO BUTTON FILLER ASSEMBLY
Model Number(s): NONE
Product File No: 20060447

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.40 (4) (c) & (7)(f) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be connected to an individual water supply or downstream of a diverter valve on a T&S pre-rinse faucet that has been modified in accordance with T&S Brass and Bronze Works, Incorporated.

This approval supersedes the approval issued on October 22, 2001, under product file number 20010337.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010337.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov