



Jim Doyle, Governor
Mary P. Burke, Secretary

November 15, 2006

CRIVITZ REDI-MIX CO.
MMC, INC.
AL SCHULTZ
2600 N ROEMER RD.
PO BOX 1137
APPLETON WI 54911

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: CRIVITZ REDI-MIX CO.
Product Name: SEPTIC, HOLDING, GREASE INTERCEPTOR OR PUMP
Model Number(s): 1000
(43.0" L.L., 26.76 GAL/IN., 48" MAX. DEPTH OF BURY, 551 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20060459

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2012.

This approval supersedes the approval issued on December 13, 2001, under product file number 20010551.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010551.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - 3/4" diameter opening in the access riser.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov