



Jim Doyle, Governor
Mary P. Burke, Secretary

December 12, 2006

FREEDOM PLASTICS INC.
JON A.SCHYVINCK
PO BOX 1488
JANESVILLE WI 53547-1488

Re: Description: FITTINGS, PVC
Manufacturer: FREEDOM PLASTICS INC.
Product Name: SCHEDULE 80
Model Number(s): 22-1/2 DEGREE ELBOW: 8, 10, 12; 45 DEGREE ELBOW: 8, 10, 12;
90 DEGREE ELBOW: 8, 10, 12; WYE: 8X8X(4 THRU 8),
10X10X(4 THRU 10), 12X12X(4 THRU 12); COUPLING, HH: 8, 10, 12; AND
INCREASER, HH AND HS: 4X8, 4X10, 4X12, 6X8, 6X10, 6X12, 8X10, 8X12, 10X12
Product File No: 20060467

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Drain piping pressurized
 - b. Effluent piping gravity flow non-perforated
 - c. Effluent piping gravity flow perforated
 - d. Sanitary drain and vent piping . . gravity flow aboveground
 - e. Sanitary drain and vent piping . . gravity flow underground
 - f. Sanitary sewer gravity flow
 - g. Storm drain and vent piping . . . gravity flow aboveground
 - h. Storm drain and vent piping . . . gravity flow underground
 - i. Storm sewer gravity flow
 - j. Subsoil drain piping gravity flow

This approval supersedes the approval issued on October 23, 2001, under product file number 20010365.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010365.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov
SBD-10564-E (N.10/97)