

December 27, 2006

SKAW PRE-CAST
JACK SKAW
26255 105TH ST.
NEW AUBURN WI 54757

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: SKAW PRE-CAST
Product Name: BIOMICROBICS HIGH STRENGTH FAST OR MICRO FAST
Model Number(s): HIGHSTRENGTHFAST 1.0 OR 1.5 AND MICROFAST 0.5 OR 0.9
Product File No: 20060516

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2011.

This approval supersedes the approval issued on April 15, 2002, under product file number 20020159.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020159.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This tank may only be used when installed with the Bio-Microbics, Inc., High Strength or Micro Fast sewage treatment apparatus.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

- This product is approved to use the following:
 - Four inch pipe inlet located in the edge of the tank cover.
 - Four inch discharge opening in riser.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Four inch pipe openings located near the bottom of the side or end wall for siphon, pump and holding tanks.
 - Steel locking cover for the access opening.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Eight inch threaded plugged opening in access cover.
 - Six-inch diameter opening in lower portion of the interior wall for siphon, pump and holding tanks.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Press Seal "Cast-A-Seal" gasket by Press Seal Gasket Corp.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov