



March 24, 2006

ANTIGO BLOCK CO., INC.  
CAL WICK  
230 MILTON ST.  
PO BOX 34  
ANTIGO WI 54409

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: ANTIGO BLOCK CO., INC.  
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, HOLDING OR PUMP  
Model Number(s): 1260/720  
(45.0" L.L., 28.1/16.3 GAL/IN., 48" MAX. DEPTH OF BURY, 957 G.P.D. WHEN USED AS A SEPTIC/SEPTIC TANK OR 606 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20060892

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2011.

This approval supersedes the approval issued on January 18, 2001, under product file number 20002280.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002280.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This product is approved to use the following:
  - Single or Dual inlet(s) and/or outlet(s) at end of tank with either one access opening above both inlets or outlets or individual access openings over each inlet and/or outlet.
  - Bottom openings for pump and holding tanks.
  - Four inch discharge opening in riser.
  - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp., or Fernco gasket model 44 V-405.
  - Four or six inch PVC coupling cast in the tank or cover wall for connection of inlet, outlet, observation or vent pipe.
  - TUF-TITE Round Riser System to be installed in accordance with the product approval issued to TUF-TITE.

ANTIGO BLOCK CO., INC.

Page 2

March 24, 2006

Product File No: 20060892

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: [mike.beckwith@wisconsin.gov](mailto:mike.beckwith@wisconsin.gov)