



January 12, 2007

WAUSAU HOMES, INC.
LEE SEIS
PO BOX 8005
WAUSAU WI 54402-8005

Re: Description: **PREFABRICATED PLUMBING SYSTEM**
Manufacturer: **WAUSAU HOMES, INC.**
Product Name: **HANDICAP 1-STORY MOTEL**
Model Number(s): **NONE ASSINGED**
Product File No: **20070020**

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2012.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on December 21, 2001 under product file number 20010510.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010510.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov