



May 14, 2007

ECOLAB, INC.  
REGULATORY AFFAIRS  
JAMISON KORTAS  
370 N. WABASHA ST.  
ST. PAUL MN 55102-1390

Re: Description: PROPORTIONER  
Manufacturer: ECOLAB, INC.  
Product Name: ELECTROMATIC AND SOLITRON 1000  
Model Number(s): ELECTROMATIC MODELS: 9257-1439 ELECTROMATIC; 9257-1520 ELECTROMATIC  
SOLITAIRE; 9257-1538 ELECTROMATIC STAINLESS POWER; 9257-1587  
ELECTROMATIC SOLID FUN; 9257-1769 ELECTROMATIC SILVER POWER AND  
SOLITRON 1000 MODELS: 9257-1157 AND 9257-1645  
Product File No: 20070061

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2012.

This approval supersedes the approval issued on August 11, 2004, under product file number 20030282.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030282.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This chemical dispensing system shall be connected to the water distribution system in either of the following manners:
  1. The fixture supply shall be individually connected to the water distribution system.
  2. The fixture supply shall be installed with a pressure bleeding device. The pressure bleeding device shall create a visually free flow of water through the atmosphere from the faucet connection into the fixture drain. The fixture supply must comply with either s. Comm 84.20 (6)(c) and 84.30 (4) or an acceptable backflow preventer must be installed on the inlet of the fixture supply connector and the outlet of the pressure bleeding device.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov