



March 6, 2007

ARJO, INC.  
GARY LOFGREN  
50 N GARY AVE  
ROSELLE IL 60172

ARJO HOSPITAL EQUIPMENT AB  
JOHN WENNBORG  
PO BOX 61  
ESLOV  
SWEDEN

Re: Description: HEALTH CARE PLUMBING APPLIANCE  
Manufacturer: ARJO HOSPITAL EQUIPMENT AB  
Product Name: MULTICLEAN DISINFECTION SYSTEM  
Model Number(s): BPA 1101-US  
Product File No: 20070066

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2012.

This approval is contingent upon compliance with the following stipulation(s):

- This plumbing product must be installed with the critical level of the vacuum breaker not less than six inches above the highest use of the hose tip of this product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov