



March 23, 2007

ARJO, INC.  
GARY LOFGREN  
50 N GARY AVE  
ROSELLE IL 60172

ARJO HOSPITAL EQUIPMENT AB  
JOHN WENNBORG  
PO BOX 61  
ESLOV  
SWEDEN

Re: Description: HEALTH CARE PLUMBING APPLIANCE  
Manufacturer: ARJO HOSPITAL EQUIPMENT AB  
Product Name: BATHING UNIT  
Model Number(s): MALIBU  
Product File No: 20070067

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2012.

This approval is contingent upon compliance with the following stipulation(s):

- The drain serving this product must have a drainage capacity of at least 16 gallon per minute.
- The water supply serving this product must meet the following conditions: Maximum static pressure of 87 psig, Minimum dynamic pressure of 7.2 psig, Minimum flow per supply pipe of 6.6 gallons per minute, and The temperature of 100 - 176 degrees F. (Recommended 140 degrees F) for the hot water supply.
- The hand-held shower does not required any additional form of backflow protection because it has an air gap discharge.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov