



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

April 20, 2007

NTA, INC.  
DAVID BARTS  
305 N OAKLAND AVE.  
PO BOX 490  
NAPPANEE IN 46550

RITZ-CRAFT CORP. OF MI, INC.  
GLEN EMRICK  
118 DEAL PKWY  
PO BOX 5  
JONESVILLE MI 49250

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: RITZ-CRAFT CORP. OF MI, INC.  
Product Name: MODULAR HOME-DWV AND WATER LINES  
Model Number(s): RANCH OR 2 STORY INSTALLATION OF: KITCHEN SINK WITH OR WITHOUT  
DISHWASHER AND/OR FOOD WASTE GRINDER (KS1, KS2, KS3, KS4); TOILET (T1);  
SINGLE BOWL VANITY OR UTILITY OR BAR SINK (VS1); WASHER BOX (WB1, WB2,  
WB3); AND TUB SHOWER (TS1) SHOWER (TS2) TUB (TS3)  
Product File No: 20070088

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2012.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.
- The maximum water supply fixture units (wsfu) on Type L copper tubing must not exceed 31.0 wsfu for 1-inch tubing, 16.5 wsfu for 3/4-inch tubing and 6.5 wsfu for 1/2-inch tubing.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov