



March 26, 2007

TERRACE HOMES  
DEBRA RIECKENBERG  
1553 11TH DR  
FRIENDSHIP WI 53934

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: TERRACE HOMES  
Product Name: MODULAR HOME - DWV LINES  
Model Number(s): THGS 14C  
Product File No: 20070126

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2012.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 20 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation of Oatey Sure-Vent 20 DFU air admittance valve for venting this system is allowed in accordance with the Oatey Sure-Vent 20 DFU Wisconsin product approval.

This approval supersedes the approval issued on January 2, 2007, under product file number 20060551.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060551.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov