



Jim Doyle, Governor
Mary P. Burke, Secretary

August 6, 2007

SPEARS MFG.CO.
JAMIE HEINZ
237 SHADY LANE
COLGATE WI 53017

SPEARS MANUFACTURING CO.
GREG PEAK
15853 OLDEN ST.
PO BOX 9203
SYLMAR CA 91392

Re: Description: FITTINGS, CPVC
Manufacturer: SPEARS MANUFACTURING CO.
Product Name: CPVC VALVES AND SCHEDULE 80 FITTINGS
Model Number(s): SCHEDULE 80 FITTINGS (ASTM F 437 or F 439).in sizes 3", 4", 6", 8", 10", 12", 14", and 16". Molded flanges (1/2" - 18"), Molded wyes (Reducing and full flow, Single and double wyes (1/2" - 24")), True Union Ball Valves and True Union Ball Check Valves, Single Entry Ball Valves and Compact Ball Valves (1/2" -6"), Utility Ball Valves and Ball Check Valves, Butterfly Valves (1-1/2" - 24").
Product File No: 20070199

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (4)(e)1 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2012.

This approval supersedes the approval issued on July 16, 2007, under product file number 20070199.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The fittings that conform to ASTM F 439 shall be labeled with manufacturer's name or trade mark, material designation CPVC for CPVC 23447 and CPVC 42 for CPVC 23448, the seal or mark of the laboratory making the evaluation for potable water contact, size, and this designation "F 439," with which the fitting complies.

Where the size of the fitting does not allow complete marking, omit identification marking in the following sequence: size, material designation, F 439, and the manufacturer's name or trademark.

- The fittings that conform to ASTM F 437 shall be labeled with manufacturer's name or trade mark, material designation CPVC for CPVC 23447, the seal or mark of the laboratory making the evaluation for potable water contact, size, and this designation "F 437," with which the fitting complies.

Where the size of the fitting does not allow complete marking, omit identification marking in the following sequence: size, material designation, F 437, and the manufacturer's name or trademark.

- This product may be installed for the following water use(s):
 - a. Cold water distribution piping Aboveground
 - b. Cold water distribution piping Underground

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov
SBD-10564-E (N.10/97)