



July 11, 2007

BIO-MICROBICS, INC.  
ALLISON BLODIG  
8450 COLE PKWY.  
SHAWNEE KS 66227

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)  
Manufacturer: BIO-MICROBICS, INC.  
Product Name: SaniTEE®  
Model Number(s): SNT 818, ST 838  
8 IN. DIA.; FLOW RANGE UP TO 6,000 AND 10,000 GPD, RESPECTIVELY.  
Product File No: 20070218

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- A means of venting the gases formed inside of the tank in which this product is installed shall be provided in accordance with s. Comm 84.25 (5), of the Wisconsin Administrative Code.
- This product must be installed in accordance with the manufacturer's installation instructions and with the bottom of the product above the scum level in the tank.
- This product shall be cleaned and maintained at the same time as the tank pumping interval.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov